

# Certificate of Constancy of Performance

This is to certify that:

ExcelAir b.v.  
Lingewei 67  
Tiel  
4004 LK  
The Netherlands

Holds Certificate Number:

2797 CPR 620853

In respect of:


## **EN 12101-3:2015 Specification for powered smoke and heat exhaust ventilators**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 are applied and that the product fulfils (products fulfil) all the prescribed requirements set out above. This certificate remains valid as long as the test methods and/or factory production control requirements included in the harmonised standard(s), used to assess the performance of the declared essential characteristics, do not change and the products(s), and the manufacturing conditions in the plants(s) are not modified significantly.

For and on behalf of BSI, a Notified  
Body for the above Regulation  
(Notified Body Number 2797):

Previous Notified Body: BSI 0086

First Issued: 2014-10-08



\_\_\_\_\_  
Drs. Dave Hagenaaars, Managing Director

Latest Issue: 2019-03-26

Page: 1 of 3

...making excellence a habit.™


# Certificate of Constancy of Performance

No. 2797 CPR 620853

**Manufacturing Plant:** Prosecco 5/b  
Sgonico  
Trieste  
34010  
Italy

## EN 12101-3:2015 - Certified scope:

CPC Car Park Fans	Model reference			
	CPC 200 S2	CPC 220 S2	CPC 250 S2	CPC 300 S2
<b>Response Delay</b>	N/A			
<b>Resistance to Fire class</b>	F300 (tested to 300°C, 120mins)			
<b>Motor Rating</b>	Class F / Class H			
<b>Ancillaries</b>	Integral Isolator 49.42015.000			
<b>BSRIA report 56144/3 refers.</b>				



First Issued: 2014-10-08

Latest Issue: 2019-03-26

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.  
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands  
A member of BSI Group of Companies.

# Certificate of Constancy of Performance

No. 2797 CPR 620853

## Manufacturing Plant

ExcelAir b.v.  
Lingewei 67  
Tiel  
4004 LK  
The Netherlands

## Certified Activities

EN 12101-3:2015 Specification for powered smoke and heat exhaust ventilators



First Issued: 2014-10-08

Latest Issue: 2019-03-26

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.  
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands  
A member of BSI Group of Companies.