Certificate of Constancy of Performance

This is to certify that:

ExcelAir b.v.
Lingewei 67
Tiel
4004 LK
The Netherlands

Holds Certificate Number: 0086-CPR-620853

In respect of:

EN 12101-3:2015 Specification for powered smoke and heat exhaust ventilators

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 are applied and that the product fulfils (products fulfil) all the prescribed requirements set out above. This certificate remains valid as long as the test methods and/or factory production control requirements included in the harmonised standard(s), used to assess the performance of the declared essential characteristics, do not change and the products(s), and the manufacturing conditions in the plants(s) are not modified significantly.

For and on behalf of BSI, a Notified Body for the above Regulation (Notified Body Number 0086):

Chris Lewis - Certification Director, Product Certification

First Issued: 2014-10-08

Latest Issue: 2017-10-23

...making excellence a habit.™

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Certificate of Constancy of Performance

No. 0086-CPR-620853

Manufacturing Plant: Prosecco 5/b
Sgonico
Trieste
34010
Italy

EN 12101-3:2015 - Certified scope:

CPC Car Park Fans	**Model reference**			
	CPC 200 S2	**CPC 220 S2**	**CPC 250 S2**	**CPC 300 S2**
Response Delay	N/A			
Resistance to Fire class	F300 *(tested to 300°C, 120mins)*			
Motor Rating	Class F / Class H			
Ancillaries	Integral Isolator 49.42015.000			
BSRIA report 56144/3 refers.				

First Issued: 2014-10-08 Latest Issue: 2017-10-23

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.